



12"-24" DUAL WALL SANITITE® HP WATERTIGHT CONNECTION USING A MANHOLE BOOT (CORED HOLE) W/ PREFABRICATED ADAPTER



NOTES:
PERFORMANCE HIGHLY DEPENDENT ON INSTALLATION. CONTRACTOR MUST ENSURE MANHOLE GASKET IS UNIFORMLY SEATED AROUND STRUCTURE ADAPTER. EXTRA PRECAUTIONS MUST BE TAKEN TO PREVENT DIFFERENTIAL SETTLEMENT BETWEEN THE PIPE AND MANHOLE.
SEE STANDARD DETAIL STD-201 AND TECHNICAL NOTE: 5.04 CONNECTIONS TO MANHOLES AND STRUCTURES FOR INSTALLATION RECOMMENDATIONS.

PIPE SIZE	ADAPTER OD	ADS ADAPTER PRODUCT CODES	PSX: DIRECT DRIVE *	CAST-A-SEAL *	KOR-N-SEAL® *	
					SERIES I OR II	SERIES 306
12" (300mm)	15.3" (388.6mm)	1222AAP	18Y OR 20Y	CAS 802	S106-20BWS	N/A
15" (375mm)	18.3" (464.8mm)	1522AAP	22M	CAS 802	S206-22	S306-22
18" (450mm)	22.0" (558.8mm)	1822AAP	26L	CAS 802	S206-26	S306-26
24" (600mm)	29.0" (736.6mm)	2422AAP	32A	CAS 802	S206-32	S306-32

* THIRD PARTY - CODES AS SUPPLIED BY MANUFACTURER
KOR-N-SEAL is a registered trademark of NPC, Inc. (www.npc.com)
PSX Systems are a product of PRESS-SEAL GASKET CORPORATION. (www.press-seal.com)

PIPE SIZE	ADAPTER OD	NYLOPLAST PRODUCT CODES	PSX: DIRECT DRIVE *	CAST-A-SEAL *	SERIES I OR II	SERIES 306
12" (300mm)	12.5" (317.5mm)	1257AGHPU2	16M	CAS 802	S106-16AW	N/A
15" (375mm)	15.3" (388.6mm)	1557AGHPU2	18M OR 20Y	CAS 802	S106-20BWS	N/A
18" (450mm)	18.7" (475.0mm)	1857AGHPU2	22M	CAS 802	S206-22	S306-22L
21" (525mm)	22.1" (561.3mm)	2157AGHPU2	26L	CAS 802	S206-26	S306-26L
24" (600mm)	24.8" (629.9mm)	2457AGHPU2	28A	CAS 802	S206-28	S306-28A

* THIRD PARTY - CODES AS SUPPLIED BY MANUFACTURER
KOR-N-SEAL is a registered trademark of NPC, Inc. (www.npc.com)
PSX Systems are a product of PRESS-SEAL GASKET CORPORATION. (www.press-seal.com)

© 2016 ADS, INC.

ADVANCED DRAINAGE SYSTEMS, INC. ("ADS") HAS PREPARED THIS DETAIL BASED ON INFORMATION PROVIDED TO ADS. THIS DRAWING IS INTENDED TO DEPICT THE COMPONENTS AS REQUESTED. ADS HAS NOT PERFORMED ANY ENGINEERING OR DESIGN SERVICES FOR THIS PROJECT, NOR HAS ADS INDEPENDENTLY VERIFIED THE INFORMATION SUPPLIED. THE INSTALLATION DETAILS PROVIDED HEREIN ARE GENERAL RECOMMENDATIONS AND ARE NOT SPECIFIC FOR THIS PROJECT. THE DESIGN ENGINEER SHALL REVIEW THESE DETAILS PRIOR TO CONSTRUCTION. IT IS THE DESIGN ENGINEER'S RESPONSIBILITY TO ENSURE THE DETAILS PROVIDED HEREIN MEETS OR EXCEEDS THE APPLICABLE NATIONAL, STATE, OR LOCAL REQUIREMENTS AND TO ENSURE THAT THE DETAILS PROVIDED HEREIN ARE ACCEPTABLE FOR THIS PROJECT.

REV.	DESCRIPTION	TJR	DATE	CHKD
12	REVISED PIPE INSERTION		05/25/16	

DRAWING NUMBER:	STD-205D
-----------------	----------

12"-24" SANITITE HP	
MH BOOT	

ADVANCED DRAINAGE SYSTEMS, INC.	4640 TRUEMAN BLVD HILLIARD, OHIO 43026
---------------------------------	---

DATE	4/3/09
SCALE	NTS
SHEET	1 OF 1